

Installation Instructions

Access 7 CE

Tehonsyöttö:
8...15 VDC 200 mA

KytKentä:

12VDC	Punainen
MAA	Musta
Rx	Harmaa
Tx	Pinkki
Rx-	Valkoinen
Tx-	Vihreä
Oven ohjaus	Violetti
Summeri	Keltainen
Vihreä led	Ruskea
Punainen led	Sininen

Suojamaa Suojavaippa (kytke laitteen ulkopuoliseen maapotentiaaliin)

Lukijoiden sijoittaminen alle 10 cm etäisyydelle toisistaan tai lukijan asentaminen metallipinnalle saattaa lyhentää lukuetaisyyttä.

Älä asenna voimakkaiden sähköhäiriölähteiden läheisyyteen.

Älä katkaise kaapelia alle 10 cm pituiseksi.

Power supply:
8...15 VDC 200 mA

Connection:

12VDC	Red
GND	Black
Rx	Gray
Tx	Pink
Rx-	White
Tx-	Green
Door control	Violet
Buzzer	Yellow
Green led	Brown
Red led	Blue

Shield Cable shield (connect to external ground, not to the device GND-pin)

If readers are placed closer than 10 cm distance from each other or if the reader is installed on metal the reading distance can be shorter.

Do not install close to sources of powerful electromagnetic disturbance.

Do not cut the cable shorter than 10 cm.

