

Installation Instructions

Access 9 CM IA

Tehonsyöttö:

10...15 VDC 200 mA

Kytkenä:

| | |
|--------|------|
| 12 VDC | Pin1 |
| MAA | Pin2 |
| TxD | Pin5 |
| RxD | Pin6 |

Huom! Sininen, vihreä, harmaa, keltainen, punainen ja ruskea johdin jätetään kytkemättä.

Lukijoiden sijoittaminen alle 10 cm etäisyydelle toisistaan tai lukijan asentaminen metallipinnalle saattaa lyhentää lukuetaisyyttä.

Älä asenna voimakkaiden sähköhäiriölähteiden läheisyyteen.

Idesco Oy vakuuttaa täten, että Access 9 CM IA lukija on direktiivin 1999/5/EY oleellisten vaatimusten ja sitä koskevien direktiivin muiden ehtojen mukainen.

Power supply:

10...15 VDC 200 mA

Connection:

| | |
|--------|------|
| 12 VDC | Pin1 |
| GND | Pin2 |
| TxD | Pin5 |
| RxD | Pin6 |

Note! Do not connect pins 3, 4 and 7.

If readers are placed closer than 10 cm away from each other or if the reader is installed on metal, the reading distance can be shorter.

Do not install close to sources of powerful electromagnetic disturbance.

Hereby, Idesco Oy, declares that this Access 9 CM IA reader is in compliance with the essential requirements and other relevant provisions of directive 1999/5/EC.

